

OVERVIEW OF Water Demand Management Initiatives: A City of Cape Town Approach

Zolile Basholo Manager: Water Demand Management and Strategy | 04February 2016

Making progress possible. Together.

Contents

- Water Value Chain of the City of Cape Town Municipality
- Water Demand and Supply History
- Strategic Goals of Water Demand Management Strategy
- City of Cape Towns Overall Water Balance
- Demand Management Interventions
- Annual Savings Achieved against Projected
- Conservation programmes







WATER VALUE CHAIN OF THE CITY OF CAPE TOWN



Water Value Chain within the City of Cape Town (Reticulation)





BULK WATER SYSTEM PROFILE

- Supplied from 14 Dams
 - Capacity of 6 major dams is 898 300 000 m³
 - 11 owned and operated by the City
 - 12 Water Treatment Plants (1 650 MI/d)
 - 26 Bulk Reservoirs (Total storage 2 740 MI)
 - Atlantis Groundwater Scheme
 - artificially recharged aquifer system
- Large diam bulk conveyance pipelines
 - 630 km
- Water quality: Controlled and monitored operationally at the WTPs and independently by Scientific Services Branch;
- Level of supply assurance from WCWSS is 97% (in terms of the Raw Water Supply Agreement between the City and the Department of Water & Sanitation)
- Population supplied: over 3.8 million
- Households served: over 1.1 million

City of Cape Town Consumer Profile

- Bulk Consumers
 - Stellenbosch Municipality
 - Drakenstein Municipality
 - Farmers
- Reticulation
 - Commercial
 - Residential
 - Industrial
 - Schools and Parks
 - Municipal
 - Informal Settlements

2014/15 Water Demand:

Bulk Consumers (External)

Annual Average Daily Demand: 103.5 Ml/day

Reticulation Consumers

Average Annual Daily Demand: 764.4 MI/day


Peak Week Demand: 1208 MI/day (Jan '14)

Peak Day Demand: **1296 MI/day** (29 Jan '14)






City of Cape Town Sector Usage (14/15 Financial Year)





Actual demand growth 1999 – 2014 vs Unconstrained growth





Factors that influenced demand growth after 2000

Water restrictions in 2000/01 and 2004/05

Water restrictions were implemented in 2000/01 and 2004/05, after periods of low winter rainfall.

The City commits to implementing WDM as part of approval of Berg River Scheme

The raw water supply agreement between the City and DWS was signed in 2003, for the construction of the Berg River Scheme. One of the conditions of approval of the Scheme was that the City would implement water demand management.

The City approves and implements a 10 year WDM Strategy

The City approved its 10 year water demand management strategy in 2007. A dedicated water demand management section was established in the City's water and sanitation department, responsible for implementing the strategy.

Berg River Scheme completed

The construction of the Berg River Scheme was completed in 2007.



Strategic Goals of Water Demand Management Strategy

Goal A:	Water Loss < 15% - Apparent loss reduction - Real loss reduction	ative 0
Goal D:	Non-revenue Water < 20% - Unbilled authorized consumption - Apparent losses - Real loss	Quantitative
Goal E:	Demand growth < 2%	
Goal B:	On-going effective management systems and implementation of Integrated Water Management Plan	Qualitative
Goal C:	Mobilise resources according to the Water Conservation and Water Demand Management Strategy.	∂Ø



CITY OF CAPE TOWN OVERALL WATER BALANCE



IWA Water Balance for 2014/15 Financial Year (Overall) in kilolitres

				External Customers	37 764 262	
	(B)	(D) Billed 266 229 322	(H) metered 266 229 322	Internal Customers	228 465 060	(Q) Revenue Water 266 229 322
	Authorised		(I) Unmetered		0	77.7%
(A)	288 394 954	(E)	(J) Metered	Informal Settlements	10 998 792	
System Input	84.2%	Unbilled	13 345 632	Formal Metered Unbilled	2 346 840]
342 696 438		22 165 632	(K) Unmetered 8 820 000	Formal Unmetered	8 820 000	(R) NRW
100%	(C)	(F) Apparent Losses	(L) Unauthorised	2 790 210	1	76 467 116
	Losses (UAW)	22 897 637	(M) Meter Inaccuracies	20 107 427	,	22.3%
	54 301 484	(G)	(N) Mains	20 834 871		
	15.8%	Real Losses	(O) Storage	300 100]
		31 403 847	(P) Connections	10 268 876		

- Top down methodology
- Water loss (and NRW) increased from last year
- Reasons:
 - Higher temperatures
 - Increased consumption (especially unbilled authorised could be underestimated) – 2015 recorded as the driest year since 1904
 - Increased fire events (volume not recorded in the WB therefore by default it would fall within the losses volume)

DEMAND MANAGEMENT INTERVENTIONS



Water demand management interventions

Technical interventions:

- District Metered Areas (DMA's)
- Pressure management
- Treated effluent use
- Water pipe replacement
- Active Leak detection and Repair (Three teams)
 - Team 1: Field Measurements
 - Team 2: Basic Leak Detection (visual surveys)
 - Team 3: Specialist non-visible leak detectors
- Water management devices
- Meter replacement
- Zone metering
- Building plumbing retrofit



Preferred real loss reduction approach (Criteria)

Real Loss Reduction Intervention	Preferred Priority Implementation Order	Relative Benefit Ranking	Relevant Cost Ranking	Relevant Implementatio n Time Ranking
Pressure Management	1	1	1	1
Active Leak Detection	2	3	2	2
Speed & Quality of Repair	3	4	3	3
Mains rehabilitation/ replacement	4	2	4	4



Pressure management projects (coupled with pipe replacement)

Khayelitsha pressure management project (2001)

Estimated savings: 9 Mm³/a



Mitchells Plain pressure management project (2008)

Estimated savings: 2.4 Mm³/a



Other notable pressure management projects, with estimated savings:


•	Mfuleni:	0.4 Mm³/a
•	Gugulethu:	2.6 Mm³/a
•	Langa:	0.5 Mm³/a
•	Eersteriver:	1.2 Mm³/a
•	Brentwood Park:	0.04 Mm ³ /a
•	Browns Farm:	0.6 Mm³/a
•	Wesbank:	0.3 Mm³/a
•	Delft:	0.6 Mm³/a
•	Grassy Park:	0.6 Mm³/a
•	Crossroads:	0.2 Mm³/a
•	Plumstead & Retreat:	0.6 Mm³/a
•	Fisantekraal:	0.2 Mm³/a
•	Marina de Gama:	0.6 Mm ³ /a




Decrease in burst main frequency

In addition:

Pipe replacement, aligned with pressure management intervention (where applicable)



	2011/12	2012/13	2013/14	2014/15
Length of water reticulation mains replaced (m)	89 975	70 270	55 418	48 622
No. of repairs to burst mains	4 085	3 306	3 213	2 569







Active Leak Detection and Repair

	2011/12	2012/13	2013/14	2014/15
No. Repairs: Connections, Meters, Sluices, Valves & Fire Hydrants	26 574	41 437	40 696	35 356
Associated Estimated Savings (kl/annum)	2 287	3 580	4 592	3 887

	2011/12	2012/13	2013/14	2014/15
No. Meters Replaced/re-fixed/relocated	8 272	5 450	5 656	6 453
No. Water Management Devices Installed	17 556	7 468	17 989	32 111
No. Repairs on connections	27 203	28 933	36 968	33 133



	Subzone's statistics							
Description	Highbury	Highbury Park	Wesbank	Mfuleni	Du noon	Pella	Totals	
	Zone's Statistics							
Length of watermains (km)	enath of watermains (km) 20.39 15.34 22.91 58.617 32.083							
Pipeline Material	Fibre cement	Fibre cement	Fibre cement	Fibre cement	Fibre cement		Fibre cement	
No. of properties	1259	943	3204	8441	3025		16872	
	located leaks statistics							
Total No. leaks located	Total No. leaks located 46 12 77 215 40 23							
Dates in Months when leaks detection was done	2013	2013	2014	2014/15	2015	2015	1.8 yrs	
Dates in Months when leaks were repaired	Fixed	Fixed	Leaks fixed except leaking meters with WMD	In planning	In planning	In planning	generally leaks are not fixed	

Industrial meter audit Investigation and illegal connections

- Infrastructure Analyse
- Prioritise according to age of the area and consumption profile
- Includes illegal connection investigation
- <u>Identify</u> damaged meters and <u>Replace</u> meters
- +/-20 industrial areas were covered
- To name a few:
 - Atlantis Industrial Area
 - Paarden Eiland
 - Athlone Industria



Speed and Quality of Repair (e.g pipe burst etc)

1st Level Response

Determine:

- repair responsibility (Municipal or Private)
- repair level, resources required
- shut-off area
- shut-off sequence, recharge sequence
- re-charge main on completion
- Monitor Pressure Zones, daily Pressure Monitoring Charts Require knowledge of infrastructure configuration

2nd Level Response

Semi-skilled Supervisor/ Driver + 2 staff + 1ton LDV + tools

- Effects minor repairs
- Meter replacements
- Repairs pipes, valves, hydrants
- Rebuild hydrant boxes
- Replace covers etc.

3rd Level Response

- Plumber/ Senior Foreman + 4 staff + 3ton Vehicle
- Install New Connections 20mm and up
- Repairs burst water mains up to 250mm

4th Level

Senior Foreman, Senior Handymen, 10 Workers, Machine Operator, 5 ton crane truck with Driver water main Replacement or new Installations Burst main repairs above 250mm



Speed and Quality of Repair

Benefits of the Levels of response

- Rapid response to complaints
- Shut down burst mains quickly (less wastage)
- Reduce risk of private damage
- Reduce risk of public liability e.g vehicles into hole
- Staff utilisation optimised, eliminate overtime



Treated Effluent Re-use

- More than 200 users are connected
- Mostly used for irrigation and industrial purposes
 - Golf courses
 - City Parks
 - Schools
 - Farmers etc
- In 2014/15 approximately 6% of potable water was off-set












SAVINGS ACHIEVED AGAINST PROJECTIONS





Current savings against projections






Water Conservation Programme



"Keep Saving Water" Website






Education and Awareness Campaigns

- Door to Door Education

EPWP Pledge





Backyard dwellers





Education and Awareness Campaigns

- Schools Intervention
















Media Coverage - Restrictions





Website

- New website launched in December
 - includes Frequently Asked Question's (FAQ's)






International Award: C40 Cities-Adaption and Implementation of the WCWDM Strategy (2015)






National Award: WCWDM Sector Award (2013)





Independent Institutions Recognition (2013 and 2014)







Thank You

For queries contact: Zolile.Basholo@capetown.gov.za